


- the section between inlet and the second static mixer must be straight and it must not contain any obstructions
- pipe bends downstream the second static mixer are allowed
- the displayed dimensions are the minimum requirements

TYPE	DIMENSION	COMMENT
D	Ø600x3mm	TUBE DIAMETER
E	491mm	
R	1118mm	MINIMUM EVAPORATION LENGTH
L	2950mm	MINIMUM TOTAL LENGTH
H	360mm	MINIMUM DISTANCE
A	1248mm	MINIMUM DISTANCE
B	891mm	MINIMUM DISTANCE

The copyright of this drawing entrusted to the recipient personally shall remain with HUG ENGINEERING AG. It is not allowed to copy, duplicate or save this drawing or to communicate or disclose it to a third party without written approval.											
						(Scale) Not applicable		(Weight) Not applicable			
						(Material) Not applicable					
						MIXING SECTION					
				DATE	Name	11436 / CPL Concordia / CPL Politecnico Mi					
			drawn	20/11/2014	ANPU						
			check.	20/11/2014	ANPU						
			status		APPROVED						
			update								
			 A Company of the ElingKlinger Group			MIX- 11436			page	of	
									1	1	
						A3					

			DATE	Name
		drawn	20/11/2014	ANPU
		check.	20/11/2014	ANPU
		status	APPROVED	
		update		
-	20/11/2014	ANPU		
Rev.	DATE	Name		

**hugengineering.**  
A Company of the ElringKlinger Group