



Roberto Gatti
 AGENZIA GATTI ROBERTO
 Strada Bertoli,64
 Parma, 43123
 Telefono: +39 0521 642 014
 Fax: +39 0521 642 014
 Cell Phone: +39 347 5424987
 E-mail: info@gattir.191.it

Progetto :
 Referenza:
 Tipo prodotto : (EU) AT/UAT Cooling Tower

Data: 12/1/2015

Pagina: 1

Criterio di Selezione		Criterio di scelta IBC	
Resa (Tons):	905.00	Carico sismico di progetto	1 g
Resa (kW):	3.979.29	(g)	
Resa (kcal/h):	3.422.231	Pressione (kN/m²)	up to 2.87
Fluido:	Acqua	:	
Portata (LPS):	140.0		
Temperatura Fluido Ingresso (°C):	36.50		
Temperatura Fluido uscita (°C):	29.70		
Bulbo Umido (°C):	24.00		

CTI/ECC Certified Cooling Tower

Q.tà	Modello	Resa (kW)	Percentuale Capacità
1	AT-114-0124L	4.023.1	101.1

Tutti i pesi, le dimensioni e i dati tecnici sono per unità

Ventilatori:	1		
# Motori Vent @ kW:	(1) @ 18,50 (415/3/50)	Lunghezza Complessiva (mm):	7.239
Portata aria (m³/s)	80.3	Larghezza Complessiva (mm):	4.248
Perdita di carico ingresso (kPa):	19.1	Altezza Complessiva (mm):	5.324
Acqua Evaporata (l/s):	1.37		
		Peso in Funzionamento (kg):	14.678
		Peso Spedizione (kg):	7.489
		Sezione più Pesante (kg):	4.840

Opzioni Selezionate

Conformità alle norme IBC (classe 1 g)

EVAPAK Fill

Fan Motor IE2 Single Speed

Griglia protezione ventilatore in accordo alla normativa CE

EVAPCO, INC.




UNIT	MODEL #	SCALE	DWG. #	REV.	DATE	SERIAL #
COOLING TOWER	AT-114-0124L	N.T.S.	T3142424-DRD-ST	-	12/01/2015	

- NOTES:
1. (M)- FAN MOTOR LOCATION
 2. HEAVIEST SECTION IS UPPER SECTION
 3. MPT DENOTES MALE PIPE THREAD
FPT DENOTES FEMALE PIPE THREAD
BFW DENOTES BEVELED FOR WELDING
 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
 5. MAKE-UP WATER PRESSURE
20 psi MIN [137 kPa], 50 psi MAX [344 kPa]


**FACE 2
PLAN VIEW**

13'-11 1/4"
[4248]




23'-9"
[7239]

FACE 1



FACE 2



FACE 1

SHIPPING WEIGHT	17010 lbs+ [7716] kg+	OPERATING WEIGHT	32860 lbs+ [14905] kg+	HEAVIEST SECTION WEIGHT	11170 lbs+ [5067] kg+	NO. OF SHIPPING SECTIONS	2
-----------------	-------------------------	------------------	--------------------------	-------------------------	-------------------------	--------------------------	---

AT-114-0124L

EVAPCO, INC.

12/01/2015

TITLE



STEEL SUPPORT CONFIGURATION

UNIT:

14x24 INDUCED DRAFT UNITS

DWG. #

SLIX1424-DD

**NOTES:**

1. BEAMS SHOULD BE SIZED IN ACCORDANCE WITH ACCEPTED STRUCTURAL PRACTICES. MAXIMUM DEFLECTION OF BEAM UNDER UNIT TO BE 1/360 OF UNIT LENGTH NOT TO EXCEED 1/2" [13mm].
2. DEFLECTION MAY BE CALCULATED BY USING 55% OF THE OPERATING WEIGHT AS A UNIFORM LOAD ON EACH BEAM. SEE CERTIFIED PRINT FOR OPERATING WEIGHT.
3. SUPPORT BEAMS AND ANCHOR HARDWARE ARE TO BE FURNISHED BY OTHERS. ANCHOR HARDWARE TO BE ASTM-A325 5/8" [16mm] BOLT OR EQUIVALENT.
4. BEAMS MUST BE LOCATED UNDER THE FULL LENGTH OF THE PAN SECTION.
5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.
6. ANCHORING ARRANGEMENT SHOWN HAS A MAXIMUM WIND RATING OF 60 PSF [2.87 kPa] ON CASSED VERTICAL SURFACES.
7. THE FACTORY RECOMMENDED STEEL SUPPORT CONFIGURATION IS SHOWN. CONSULT THE FACTORY FOR ALTERNATE SUPPORT CONFIGURATIONS.
8. UNIT SHOULD BE POSITIONED ON STEEL SUCH THAT THE ANCHORING HARDWARE FULLY PENETRATES THE BEAM'S FLANGE AND CLEARS THE BEAM'S WEB.

EVAPCO AT-114-0124L PERFORMANCE CURVE

